



ITEMS INSTALLED BY THE MEMBER:

1. 6"x 6"x 10' MIN. FULLY PRESSURE TREATED POST
2. 2" GALVANIZED RIGID STEEL CONDUIT WITH CAPS ON TOP
3. C CHANNEL STRUT AND PIPE STRAPS
4. CLASS 200 SERVICE ENTRANCE EQUIPMENT (PER NEC)
5. METER BASE SUPPLY LUGS TO SUPPORT #4/0 WIRE
6. INSULATED REDUCING BUSHING AND LOCKNUT
7. 3" SCH 80 GREY CONDUIT EXTENDING BELOW GRADE
8. 3" PVC EXPANSION JOINT - GREY
9. 3" SCH 80 24" - 36" RADIUS SWEEP
10. 3" SCH 40 GREY CONDUIT FROM IPL EQUIPMENT
(USE SWEDGE STYLE COUPLERS ONLY)
11. FACTORY BUILT METER PEDESTAL
12. SERVICE CONDUIT IN ACCORDANCE WITH NEC
13. GROUND WIRE IN ACCORDANCE WITH NEC
14. GROUND RODS IN ACCORDANCE WITH NEC
15. SERVICE CONDUCTORS TO LOAD IN ACCORDANCE WITH NEC

ITEMS INSTALLED BY THE UTILITY:

16. SERVICE WIRE FROM TRANSFORMER TO METER LOCATION
17. METER

PEDESTAL LOCATION REQUIREMENTS:

- METER BASE MUST HAVE 10' OF WORKING SPACE IN FRONT.
- MINIMUM 10' CLEARANCE FROM PEDESTAL TO THE TRANSFORMER.
- MAXIMUM OF 150' TOTAL LENGTH FROM PAD MOUNT OR POLE MOUNT TRANSFORMER TO METER PEDESTAL.