

**NOTES:**


METER BASE AND CONDUIT MUST BE INSTALLED BEFORE UTILITY INSTALLS SERVICE LINE  
 METER BASE AND CONDUIT MUST BE MOUNTED ON THE OUTSIDE WALL, FLUSH MOUNT METER BASES ARE NOT ALLOWED

**ITEMS INSTALLED BY THE MEMBER:**

- 1. METER BASE CL200
- 2. INSULATING BUSHING AND LOCKNUT
- 3. 2" SCH 80 GREY CONDUIT EXTENDING 18" MIN. BELOW GRADE
- 4. CONDUIT STRAP
- 5. 2" PVC EXPANSION JOINT - GREY
- 6. 2" SCH 40 GREY CONDUIT FROM IPL EQUIPMENT, 24" RADIUS SWEEP MIN.
- 7. UFER GROUND AND WIRE IN ACCORDANCE WITH NEC

**ITEMS INSTALLED BY THE UTILITY:**

- 8. SERVICE WIRE FROM TRANSFORMER TO METER LOCATION
- 9. METER

ITEM	MATERIAL	ITEM	MATERIAL
ENGINEER:	NEW CONSTRUCTION SPECIFICATIONS PERMANENT, WALL MOUNT URD 200A SERVICE IN DEVELOPMENT	 <b>INLAND POWER AND LIGHT CO.</b>	
REVISED	IPL DEC-11	IPL SEPT-19	DEVELOPMENT CONNECT-200A