

NOTES:


METER BASE MUST BE INSTALLED BEFORE UTILITY INSTALLS SERVICE LINE
 METER BASE AND CONDUIT MUST BE MOUNTED ON THE OUTSIDE WALL, FLUSH MOUNT METER BASES ARE NOT ALLOWED

ITEMS OWNED AND INSTALLED BY THE MEMBER:

ITEMS OWNED AND INSTALLED BY THE UTILITY:

1. METER BASE (RESIDENTIAL CL 320 – LEVER BYPASS PREFERRED)
2. INSULATING BUSHING
3. TERMINAL ADAPTER AND LOCK WASHER
4. CONDUIT STRAP
5. CONDUIT– EXTENDING A MINIMUM OF 18" BELOW FINISH GRADE
(2"–200A, 3"–400A) GREY SCH 80 PVC
6. LOCK WASHER
7. GROUND RODS AND WIRE IN ACCORDANCE WITH NEC

8. METER
9. SERVICE LINE IN CONDUIT

ITEM	MATERIAL	ITEM	MATERIAL
ENGINEER:	NEW CONSTRUCTION SPECIFICATIONS PERMANENT, WALL MOUNT UNDERGROUND 0-200A and 400A SERVICE	 INLAND POWER AND LIGHT CO.	
REVISED	IPL DEC-11	IPL JAN-16	PERM UG 0-400A