

**NOTES:**


METER BASE AND CONDUIT MUST BE INSTALLED BEFORE UTILITY INSTALLS SERVICE LINE  
 METER BASE AND CONDUIT MUST BE MOUNTED ON THE OUTSIDE WALL, FLUSH MOUNT METER BASES ARE NOT ALLOWED

ITEMS INSTALLED BY THE MEMBER:

1. METER BASE CL200 OR CL320 (FOR CL320 LEVER BYPASS PREFERRED, REQ'D FOR COMMERCIAL SERVICE)
2. INSULATING BUSHING AND LOCKNUT (REDUCER IF REQ'D)
3. 3" SCH 80 GREY CONDUIT EXTENDING 18" MIN. BELOW GRADE
4. CONDUIT STRAP
5. 3" PVC EXPANSION JOINT - GREY
6. 3" SCH 40 GREY CONDUIT FROM IPL EQUIPMENT, 24" RADIUS SWEEP MIN.
7. UFER GROUND AND WIRE IN ACCORDANCE WITH NEC

ITEMS INSTALLED BY THE UTILITY:

8. SERVICE WIRE FROM TRANSFORMER TO METER LOCATION
9. METER

ITEM	MATERIAL	ITEM	MATERIAL
ENGINEER:	NEW CONSTRUCTION SPECIFICATIONS PERMANENT, WALL MOUNT UNDERGROUND 0-200A and 400A SERVICE	 INLAND POWER AND LIGHT CO.	
REVISED	IPL DEC-11	IPL SEPT-19	PERM UG 0-400A