


ITEMS OWNED AND INSTALLED BY THE MEMBER:

1. CLASS 320 METER BASE – LEVER BYPASS PREFERRED
(HEAVY DUTY LEVER BYPASS REQUIRED FOR COMMERCIAL SERVICE)
2. INSULATING BUSHINGS AND LOCKNUT
3. CONDUIT STRAPS ANCHORED TO UNISTRUT, 2' ON CENTER
4. 3" SCH 80 GREY SERVICE CONDUIT, EXTENDING 18" BELOW GROUND
5. GROUND RODS AND GROUND WIRES IN ACCORDANCE WITH NEC
6. SERVICE CONDUCTORS TO LOAD IN ACCORDANCE WITH NEC

ITEMS OWNED AND INSTALLED BY THE UTILITY:

7. METER
8. SERVICE LINE IN CONDUIT FROM TRANSFORMER TO METER LOCATION

ITEM	MATERIAL	ITEM	MATERIAL
ENGINEER:		NEW CONSTRUCTION SPECIFICATIONS PERMANENT 400A METER PEDESTAL	
		 INLAND POWER AND LIGHT CO.	
REVISED	IPL DEC-11	IPL JAN-16	400A PED